SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

## **HMTX Industries, LLC**

29 Oakwood Avenue, Norwalk, CT, United States

For the following product(s):

## **Polymeric Flooring:**

Teknoflor® CS Sheet

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore<sup>®</sup>

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-05596

Valid from: March 1, 2024 to November 30, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.







2,26