

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# Jilin Forest Industry Jinqiao Flooring Group Co., Ltd.

#9788 North, Kaixuan Road, Kuancheng District, Changchun City, Jilin, China

For the following product(s):

## Engineered Hardwood:

Multi-Layer Engineered Hardwood Flooring *Maximum thickness 19mm*

Three-Layer Engineered Hardwood Flooring *Maximum thickness 22mm*

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-04300

Valid from: January 1, 2024 to December 31, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION  
BODY



A handwritten signature in black ink.

Nicole Munoz, Vice President

SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA